



ESCALA 1:100

Va a TD1-12A-PB-N

DEMANDA: 5 KVA
Tablero 3ø- 20 Espacios

TD1-12A-PB-N

1P-20A	RESERVA 7 ESPACIOS
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T12 - PROYECTOR
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T11 - PROYECTOR
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T1X - PROYECTOR
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	STE - SECADOR DE MANO
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	STD - SECADOR DE MANOS
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T3C - TOMAS
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T2B - TOMAS
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-16A	T1A - TOMAS
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	CSE - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C4D - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C3C - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C2B - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C1A - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	

Va a TD1-12B-PB-N

DEMANDA: 5KVA
Tablero 3ø- 20 Espacios

TD1-12B-PA-N

1P-20A	RESERVA 7 ESPACIOS
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T12 - PROYECTOR
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T11 - PROYECTOR
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T1X - PROYECTOR
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	STE - SECADOR DE MANO
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	STD - SECADOR DE MANOS
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T3C - TOMAS
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-20A	T2B - TOMAS
12F+12 (N)+14 (T) AVG. - THHN Ø1/2"	
1P-16A	T1A - TOMAS
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C3P - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C4H - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C3G - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C2F - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	
1P-16A	C1G - ILUMINACION
12F+12 (N) AVG. - THHN Ø1/2"	